Water Test Report

To,
SND English Medium Public School (CBSE)
Babhulgaon Tal Yeola Dist Nashik 423401

Name of Customer	**SND English Medium School (CBSE)**	**Date of report**	**16.04.2024**
Address	**Babhulgaon (Bk) Tal Yeola Dist Nashik**	**Test Report No**	**WTR/2024/Yeola/0067**
Contact No	**9552873252**	**Lab Code**	**WTR/2024/Yeola/0067/038**
Type of Sample	**Water**	**URL No**	**WTC/112894235841/024/WT**
Sample Description	**1 Liter Plastic Bottle**	**Date of Collection**	**15/04/2024**
Date of Start Analysis	**15/04/2024**	**Date of completion**	**16/04/2024**
Gat No	**Babhulgaon Bk 68/4**	**Sample Quantity**	**01 liter**

following test report is given on the basis of given actual sample on 15/04/2024. This report is valid till 03 months only.

Sr. No	Parameter	Unit	Test Method	Limits	Results	Remarks
1.	सामू (pH)	-	ABRD/STP/CH-04	6.5 - 8.4	7.10	सर्वसाधारण (Optimum)
2.	विद्युत वाहकता (Electrical Conductivity)	dS/m	ABRD/STP/CH-04	0 - 3.0	0.123	सर्वसाधारण (Optimum)
3.	एकूण विद्राव्य क्षार (Total Dissolved Solids)	mg/L	ABRD/STP/CH-04	0 – 2000	58	सर्वसाधारण (Optimum)
4.	कॅल्शियम (Calcium)	meq/L	ABRD/STP/CH-04	< 20	<0.1	सर्वसाधारण (Optimum)
5.	मॅग्नेशिअम (Magnesium)	meq/L	ABRD/STP/CH-04	< 5	0.78	सर्वसाधारण (Optimum)
6.	क्षार (Sodium)	meq/L	ABRD/STP/CH-04	< 3	<0.1	सर्वसाधारण (Optimum)
7.	कार्बोनेट (Carbonate)	meq/L	ABRD/STP/CH-04	< 0.1	< 0.1	सर्वसाधारण (Optimum)
8.	बायकार्बोनेट (Bi-Carbonate)	meq/L	ABRD/STP/CH-04	< 10	0.32	सर्वसाधारण (Optimum)
9.	क्लोराईड (Chloride)	meq/L	ABRD/STP/CH-04	< 4	1.33	सर्वसाधारण (Optimum)
10.	गंधक (Sulphur)	meq/L	ABRD/STP/CH-04	< 20	0.1	सर्वसाधारण (Optimum)
11.	नायट्रेट – नत्र (Nitrate-Nitrogen)	mg/L	ABRD/STP/CH-04	< 5	2.45	सर्वसाधारण (Optimum)
12.	स्फुरद (Phosphorus)	mg/L	ABRD/STP/CH-04	< 2	< 0.2	सर्वसाधारण (Optimum)
13.	पालाश (Potassium)	mg/L	ABRD/STP/CH-04	< 2	< 1	सर्वसाधारण (Optimum)
14.	लोह (Iron)	mg/L	ABRD/STP/CH-04	< 5	< 0.1	सर्वसाधारण (Optimum)
15.	मंगल (Manganese)	mg/L	ABRD/STP/CH-04	< 0.2	< 0.1	सर्वसाधारण (Optimum)
16.	जस्त (Zinc)	mg/L	ABRD/STP/CH-04	< 2	< 0.1	सर्वसाधारण (Optimum)
17.	तांबे (Copper)	mg/L	ABRD/STP/CH-04	< 0.2	< 0.1	सर्वसाधारण (Optimum)
18.	बोरॉन (Boron)	mg/L	ABRD/STP/CH-04	< 2	< 0.1	सर्वसाधारण (Optimum)

To,
SND English Medium Public School (CBSE)
Babhulgaon Tal Yeola Dist Nashik 423401

signature with the Seal : .....
Name : .....
Designation :.....
Name & Address of the Office / Department :.....

वैद्यकीय अधिकारी
प्राथमिक आरोग्य केंद्र, पाटोदा
ता. येवला, जि. नाशिक